

McGoff-Bethune, Inc.
5970 Unity Drive Suite A
Norcross, GA 30071
770-840-9811

Certificate of Non-Compliance

McGoff-Bethune
5970 Unity Dr. Suite A
Norcross, GA 30071

Model of Standard: Barber-Colman PA-39
Serial No.: 0945-0002
Expiration Date: 11/24/98

Manufacturer: Barber-Colman
Model: 5642-02030-330-0-00 Controller
Input Range: 0 to 2500 Units:
Input Type: TC-K **Serial No.:** X2927-2039
Tolerance: +/- .25% of span (2 deg.) +/-

Input	As Found	As Left	Error
100	130		
500	550		
1000	1090		
1500	1700		
2000	2504		

Comments Unit will not calibrate

We recommend this unit be repaired to maunfacturer's specifications

Service Technician: _____ **Date:** 4/24/98

This form when completed, signed and dated by the technician performing the calibration is a verified document of indicated results.. The above unit has been tested with an instrument that has been calibrated and tested using standards which are traceable to the National Institute of Standards and Technology, **per MIL-STD-45662A and conforms to 10CFR, Part 21.**